

File No: S2166 CCN: UUFX
Service Center No: 0
Expires: 03/22/2018
Issued: 03/22/2013



CENTRAL STATION - FIRE FIRE ALARM SYSTEM CERTIFICATE (NFPA 72)

THIS CERTIFIES that the *Alarm Service Company* is included by UL LLC in its Directory as qualified to use the *UL Listing Mark* in connection with the certificated *Alarm System*. This Certificate is the *Alarm Service Company's* representation that the *Alarm System* including all connecting wiring and equipment has been installed and will be maintained in compliance with requirements established by UL. This Certificate does not apply in any way to the installation of any additional signaling systems, such as; fire, smoke, waterflow, burglary, holdup, medical emergency, or otherwise, that may be connected to or installed along with the Certificated *Alarm System*. This Certificate does not apply in any way to the communication channel between the protected property and any facility that monitors signals from the protected property unless the use of a UL listed or Classified Alarm Transport Company is specified on the Certificate.

LIMITATION OF LIABILITY: UL LLC makes no representations or warranties, express or implied, that the Alarm System will in all cases prevent any loss by fire, smoke, water damage, burglary, hold-up or otherwise, or that the Alarm System will in all cases provide the protection for which it is installed or intended. By the Alarm Service Company providing this Certificate and the Protected Property acceptance of this Certificate, the Alarm Service Company and the Protected Property acknowledge and agree that UL does not assume or undertake to discharge any liability of the Alarm Service Company or any other party. UL is not an insurer and assumes no liability which may result directly or indirectly from inspection of the equipment, failure of the equipment, failure to conduct inspections, incorrect certification, nonconformity with requirements, failure to discover nonconformity with requirements, cancellation of the Certificate or withdrawal of the Alarm Service Company from inclusion in UL's Directory prior to the expiration date appearing on this Certificate.

OPERATIONAL REQUIREMENTS: The *Alarm Service Company* bears the responsibility for the correctness of the installation; maintenance of the system documentation; periodic system inspection and testing; maintaining and providing any necessary repairs. All operations and maintenance shall be conducted in the manner prescribed by the NFPA standard referenced. All required service is to be provided for in an appropriate contract. System documentation is defined to include any "As Built Drawings"; the records of any "Acceptance Testing"; and the records of all periodic system testing and maintenance.

SYSTEM DESCRIPTION: This system is installed and operated in accordance with standard NFPA 72, 1993 edition.

Area Covered: Building
Authority Having Jurisdiction: Pacific Grove Fire Department
Responding Fire Department: Pacific Grove Fire Department

SYSTEM DEVIATIONS FROM REFERENCED NFPA STANDARDS

No Sprinkler Supervision

Protected Property:

POINT PINOS LIGHTHOUSE
ASILIMAR & LIGHTHOUSE
PACIFIC GROVE, CA 93950

Alarm Service Company:

SENTRY ALARM SYSTEMS OF AMERICA INC,
DBA SENTRY ALARM SYSTEMS
8 THOMAS OWENS WAY
MONTEREY CA 93940

SN: FC31573068

File No: S2166 CCN: UUFX
Service Center No: 0
Expires: 03/22/2018
Issued: 03/22/2013
Entry No: 5280089 Version: 7



**CENTRAL STATION - FIRE
FIRE ALARM SYSTEM CERTIFICATE DESCRIPTION
FOR Certificate Serial No: FC31573068**

Protected Property:

POINT PINOS LIGHTHOUSE
ASILIMAR & LIGHTHOUSE
PACIFIC GROVE, CA 93950

Alarm Service Company:

SENTRY ALARM SYSTEMS OF AMERICA INC,
DBA SENTRY ALARM SYSTEMS
8 THOMAS OWENS WAY
MONTEREY CA 93940

System Description:

Area Covered: Building
Authority Having Jurisdiction: Pacific Grove Fire Department
Responding Fire Department: Pacific Grove Fire Department
Testing and Maintenance Contract date: 11/13/2013

SYSTEM DEVIATIONS FROM REFERENCED NFPA STANDARDS

No Spinkler Supervision

Automatic Fire Detection and Alarm Service

Coverage is Total
4 - Smoke Detectors : 0 - Ionization 4 - Photoelectric
9 - Other Detectors : Wireless Smoke Detectors

Manual Fire Alarm and Guard's Tour Supervisory Service

1 - Manual Fire Alarm Box

Alarm Notification and Annunciation Devices

2 - Audible/Visual Signals : Type - Strobe

Control and Transmitter Unit

Ademco ,Vista 100

Remote Monitoring

UL Listed Central Station
File: s2166, Service Center Number: 0
SENTRY ALARM SYSTEMS OF AMERICA INC,
DBA SENTRY ALARM SYSTEMS
8 THOMAS OWENS WAY
MONTEREY CA 93940

Alarm Retransmission to Fire Department

Public Telephone Network and Public Telephone Network

Alarm Transmission Method: Digital Alarm Communicator